



## Emergency Response Plan for Pools:

### HOT TUB OPERATIONS:

- The chemicals checked are chlorine and acid levels. They are checked daily.
- Chemical levels, flow rates, and temperatures

Chemical	Level
Chlorine	5.0
Acid	7.2TH
Flow Rate	60-80 Flow rate per minute
Temperature	102

- Backwash/chlorine shock treatment/drain-refill occur
  - a. Every three weeks in summer
  - b. Every two weeks in Winter
  - c. Cartridges filters changed twice per year and cleaned every 60 days
- Chemical Imbalances
  - a. If PH too low, add soda ash to raise it
  - b. If PH too high, add acid to lower it
- Chlorine levels too high (over 10 parts per million), hot tub drained and refilled

### Water emergencies:

- Fecal Matter discharge. Upon detection, Spa will be immediately closed. Time and date must be documented and a brief description of the event. The affected body of water will be super chlorinated to EPA standards for 24 hours before re- testing and re-opening.
- Sudden Illness - Move the victim away from the pool or spa area. Assess whether the victim requires EMS response. Document date and time and give a brief description of the event.
- Drownings- If the victim cannot respond or breathe. Remove victim from body of water to provide CPR. CALL 911.

### Rescue Protocol-

- If you are the first responder remove shoes and heavy garments before entering the spa. Vocalize the need for additional help if necessary. Place the victim in a safe area. Assess their condition. Contact EMS 911 if warranted. Document the event.
- Injuries- Assess the severity of the injury. Provide basic first aid and call EMS 911 if necessary.
- Facility equipment locations: Rescue gear is located on the wall. A First Aid kit is located in the office.
- Emergency stop buttons are located inside the hot tub area on the east side. They are labeled with red with emergency shut off

### **Available Equipment:**

Life Ring and Shepherds Crook

### **EMERGENCY**

**Call 435-640-1532 or 801-865-3176 for non-threatening injuries.**

### **EMS (Emergency Medical Services)-911**

#### **Chemical spills and contamination**

If a spill is discovered immediately open emergency doors on the first floor and prop open LOBBY front doors.

If you can do so safely, determine what the spill is. Report it to property management. **Call 435-640-1532 or 801-865-3176 for non-threatening injuries.**

Contact Park City Fire if the spill and cleanup is not manageable or in doubt.

Contamination to humans- Use all available water sources to dilute. Proceed directly to Park City Urgent care two blocks away. 1750 Sidewinder, Park City UT 84060

#### **Chain of command**

Operations Manager- Loretta Haslock 435-640-1532

Property Manager- Maria Johnson 801-865-3176

**The Property Manager will contact the family of the victim for all injuries or death.**

#### **Roles and Responsibilities of Staff**

EMS point of Contact- First on Scene. Call 911 Fire department when in doubt.

#### **Fire Monitoring Panels**

The fire alarm system is monitored in the office. All alarms will be seen inside the monitoring panel inside the office. Office Door code is 5410.

#### **Fire sprinkler locations:**

Call the Fire department for shut off  
Risers are located in basement

**False alarm issues.** When an alarm is reported please call the Operations Manager immediately to reset the alarm.